

30Nm On/Off, R/L & Modulating Damper Actuators

sue Number 7.1 13/10/2021



Features and Benefits

- Maintenance-free
- Position indication
- Reversible rotation
- Mechanically set rotation limits
- Manual override

Technical Overview

The VA-30 range of actuators require either a 24Vac/dc or 230Vac supply depending on version ordered. They are available to accept either an on/off/floating (raise/lower) or modulating control signal input. They also have auxiliary switch option.

The direction of rotation can be reversed by a simple selector switch. The actuator is overload-proof, and requires no limit switches and automatically stops when the end stop is reached.

Product Codes

VA-30A-24 24Vac/dc 30Nm on/off or Floating actuator

VA-30A-24S 24Vac/dc 30Nm on/off or Floating actuator

with auxiliary switches

VA-30A-230S 230Vac 30Nm on/off or Floating actuator

with auxiliary switches

VA-30M-24S 24Vac/dc 30Nm Modulating actuator with

auxiliary switches

Specification

Power supply:

VA-30x-24 19-29Vac/dc (24V nominal) VA-30A-230 85-265Vac (230V nominal)

Max. power consumption:

Running 3W Stopped 1.5W

Connection Via 1m flying lead (halogen free)

Angle of rotation 0° - 95° Running time <150s / 90°

Damper coupling:

Square 9-18mm Round 9-26mm

Damper size Up to approx. 6m²

Protection IP54

Aux. switch rating SPDT 5(2.5)A @250Vac Service life >60000 cycles (0°-95°-0°)

Ambient:

Temperature -30 to +50°C RH 5 to 95% RH

Protection class

VA-30x-24 III
VA-30x-230 II

Conformity CE

Country of origin Germany

Conformity* EMC, LVD, CE & UKCA Marked Conformity EMC, CE & UKCA Marked

WEEE Directive:



At the end of the products useful life please dispose as per the local regulations. Do not dispose of with normal household waste Do not burn.



^{*} Actuators with auxiliary switches only

30Nm On/Off, R/L & Modulating Damper Actuators

sue Number 7.1

Installation

- 1. Ensure that all power is disconnected before carrying out any work on the damper actuator.
- 2. Attach the actuator to the damper spindle, finger tighten the nuts on the V-clamp.
- 3. Fix the anti-rotation device to the back of the actuator. This is supplied connected to the back of the housing, to release simply buckle.
- 4. Move the damper to the closed position. Using the manual override push button, turn the clamp until the actuator is in the correct position and tighten the V-clamp.
- 5. If the damper has no fixed stops of its own, the angle of rotation / working range can be adjusted mechanically by re-positioning the adjustable stops.
- 6. Terminate the cores of the flying lead as required and ensure that the voltage is within the specified tolerances.


Operating Modes & Connections


2-Point

Through connecting the power supply to BU+BN (1+2) and the direction of rotation switch on position "R" moves the actuator to position 1. Is also BK (1+2+3) connected to the power supply the actuator is moving to position 0.

3-point

Through connecting the power supply to BU+BN (1+2) and the direction of rotation switch on position "R" moves the actuator to position 1. If the power supply is interrupted the actuator maintains its current position. Is also BU+BK (1+3) connected to the power supply the actuator is moving in direction 0





Rotary direction switch

R/CW= clockwise L/CCW= counter clockwise




Modulating


Through connecting the power supply to BU+BN (1+2) and a reference signal Y to BK (3) of 0(2)...10Vdc, moves the actuator to its specified position. The actual damper position 0...100% is a feedback signal U for example to share the signal with other actuators.

Mode-switch

Measure on angular range

- Actuator power-off
- Setting the mechanical end stops
- Connecting the actuator to the power supply
- -ut Dip 4 to "ON"
- Actuator is measuring on angular range
- "Y" refers to the measured angular range






30Nm On/Off, R/L & Modulating Damper Actuators

le Number 7.1

Operating Modes & Connections (continued)

Adjustment of auxiliary switches



Dimensions

